

Annexure C

**PROFORMA FOR SAFE DRINKING WATER & SANITORY
CONDITION CERTIFICATE**

File No. S.W.S.C.C /02/2025-26

Date : 31-07-2025


It is certified that an inspection team headed by Rural Drinking Water and Sanitation Sub Division, Chitradurga, inspected the D.V.S.H.S. Bharamasagara, Chitradurga Taluk and Dist.Karnataka on 30-07-2025 and on the basis of water test report attached bearing No. R.O. 25004 dated on : 27-06-2025 of Rural Drinking Water and Sanitation Division Chitradurga Certificated that the D.V.S. H.S. has safe drinking water facilities for the students and members of staff of the institution. The School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Cerntral/State/U.T.Govt.

The above is valid for a period of One year.

Signature with Seal

Name:

Shivamurthy


ನಿರ್ದೇಶಕರು ರೂರಲ್ ಡ್ರಿಂಕಿಂಗ್ ವಾಟರ್
ಅಂಡ್ ಸಾನಿಟೇಷನ್ ಸಬ್ ಡಿವಿಷನ್,
ಚಿತ್ರದುರ್ಗ, ಕರ್ನಾಟಕ.

Asst. Executive Eng
Rural Drinking water
& Sanitation
Sub-Division, Chitradurga


Name & Address of the Officer Department

To,

D.V.S. H.S.

Bharamsagara

Chitradurga Taluk And Dist.


PRINCIPAL
D.V.S.H.S.,
BHARAMASAGARA,
Chitradurga Tq, Di.


Secretary
Davanagere Veeranna Vidyasamsthe (R)
Bharamasagara-577 519
Chitradurga Tq. & Dist.

**RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK**Chitradurga District Water Quality Testing Laboratory
ZillaPanchayathPremesis, Stadium Road, Chitradurga - 577501**TEST REPORT**To
D.V.S Residential English Medium School
D.V Sharanappa Layout, VidyaNagara
Bharamsagara
Chitradurga - 577501
Contact Number: +91 9972768681Report date :27-06-2025
Report Number : 250040
Reference : Test Request Form
Sample receipt date : 26-06-2025
Sample code : CHD2500040
Analysis start date : 26-06-2025
Analysis completion date : 27-06-2025
Sample collection protocol : NA
Sample quantity : 1000ml

Sample Particulars: RO Water

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
1	pH Value @Temp25°C	8.35	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @Temp25°C	101.6	–	–	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2017
5	Colour, Hazen Units	1	5	15	IS 3025 (Part-4) :2021
6	Turbidity, NTU	0.1	1	5	IS 3025 (Part-10) : 1984
7	Total Dissolved Solids@ 180°C, mg/l	46.8	500	2000	IS 3025 (Part-16) : 1984
8	Alkalinity as CaCO_3 , mg/l	17	200	600	IS 3025 (Part-23) : 1986
9	Total Hardness as CaCO_3 , mg/l	11	200	600	IS 3025 (Part-21) : 2009
10	Calcium as Ca, mg/l	2.6	75	200	IS 3025 (Part-40) : 1991
11	Magnesium as Mg, mg/l	1.1	30	100	IS 3025 (Part-46) : 1994
12	Chloride as Cl, mg/l	8.0	250	1000	IS 3025 (Part-32) : 1988
13	Sulphate as SO_4 , mg/l	2.1	200	400	IS 3025 (Part-24) : 2022
14	Fluoride as F, mg/l	0.19	1	1.5	APHA 23 rd Edition
15	Nitrate as NO_3 , mg/l	1.7	45	No relaxation	APHA 23 rd Edition
16	Iron as Fe, mg/l	0.1	1	No relaxation	IS 3025 (Part-53) : 2003

Remarks : The above tested sample meets the requirement of IS 10500:2012 RA 2018 drinking water specification for the above tested parameters only.

Analysed by Checked by
Junior Analyst : Vinutha T

Senior Analyst : SwathiNadig N P

RDWSD/WQMSP/TeR/01

NOTE:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.

End of Test Report

PRINCIPAL

D.V.S.H.S,
BHARAMASAGARA,
Chitradurga Tq, Di.

Secretary

Davanagere Veeranna Vidyasamthe (R)
Bharamasagara-577 519
Chitradurga Tq. & Dist.Rural water and Sanitation
Division, Chitradurga